

Kyle C. Arlington  
Superintendent



Dana L. Chibbaro  
Principal

Vincent A. Gonnella  
Business Administrator  
Board Secretary

Kenilworth Public Schools  
David Brearley Middle-High School

www.kenilworthschools.com  
401 Monroe Avenue  
Kenilworth, New Jersey 07033  
908-931-9696

Dr. Kayla Lott  
Assistant Principal

## Drinking Water Sample Results

### Requirements for Initial Testing

- Districts shall conduct lead sampling and analysis at all drinking water outlets within one year. Drinking water outlets are defined as any location at a school facility, other facility, or temporary facility where water is expected to be used for consumption or food preparation.
- Sampling shall be conducted in accordance with a Lead Sampling Plan and a Quality Assurance Project Plan (QAPP).
- Analysis shall be conducted by a certified laboratory.
- Within 24 hours after reviewing and verifying the results the board of education shall make the test results of all water samples publicly available at the facility and on their website.
- If any results exceed the permissible lead action level then written notification to the parents/guardians of all students attending the facility as well the Department of Education must be made.

### Name of NJ Certified Laboratory who performed the analytical testing:

**Name:** SGS North America INC. – Environment, Health & Safety  
2235 US Highway 130  
Dayton, New Jersey, 08810

### The results are listing in the following table.

School	Sample Name	Lab Sample ID	Sample Location	Results (ppb)
Brearley	BD-FIELD BLANK	JC98907-1	Control Sample	0.50
Brearley	BD-POE	JC98907-2	Principal Bathroom Sink	3.17
Brearley	BD-POE-F	JC98907-3	Principal Bathroom Sink (Flush Sample)	.660
Brearley	BD-WC-30	JC98907-4	Drinking Fountain - Weight Room	6.90
Brearley	BD-WC-30-F	JC98907-5	Drinking Fountain - Weight Room (Flush Sample)	2.12
Brearley	BD-S-31	JC98907-6	Trainer's Room Sink (Filling Station)	1.38
Brearley	BD-POE2	JC98907-8	Principal Bathroom Sink (Final Sample)	.658